



**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



Facility Information Section

Satisfactory

Permit Number: 13-51-16151
Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: James Barker Phone: 305-532-4515
Name of Facility: Miami Beach Sr. HS
Address: 2231 Prairie Avenue
City, Zip: Miami Beach 33139

Inspection Results Information Section

Purpose: Routine	Begin Time: 01:00 PM	Correct By: Next Inspection
Inspection Date: 9/9/2015	End Time: 02:45 PM	Re-Inspection Date: None

Additional Information Section

CENSUS	2444
FEMALES	1290
MALES	1154

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings Section

SCHOOL SANITATION 1. School Site 2. Playground Equipment 3. Athletic Equipment BUILDINGS 4. Construction X 5. Maintenance & Repair 6. Lighting/Foot-Candles 7. Heating, Ventilation, A/C 8. Natural Ventilation 9. Mechanical Ventilation SANITARY FACILITIES 10. Provided/Accessible	11. Cleanliness & Repair 12. Toilet Facilities 13. Separation of Sexes 14. Fixture Ratio 15. Handwash Facilities X 16. Showers/Fixtures 17. Shower Water Temp. WATER SUPPLY 18. Installed/Operated/Maintained 19. Drinking Fountains 20. Approved Source LIQUID/SOLID WASTE 21. Sewage Disposal	22. Solid Waste VECTOR/VERMIN CONTROL 23. Infestation/Control 24. Brush/Trash 25. Water Collection/Drainage SAFETY 26. First Aid Kit FOOD 27. Food Insp. Rpt. OTHER 28. 29.
---	---	--

General Comments Section

No General Comments Available

Violations Comments Section

Inspector Signature:

Client Signature:



STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

5. Maintenance & Repair

Repair door hole in cafeteria (door plate pushed in)

Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

16. Showers/Fixtures

Provide shower curtains in boys and girls locker room in all stalls

Showers/Fixtures 64E-13.004(6)(c). Shower facilities shall be provided in all secondary schools where physical education is a required subject. Shower rooms & stalls shall have floors, partitions & walls to a minimum height of six (6) feet finished with dense non-absorbent & non-corrosive materials having a smooth impervious surface. One (1) shower head shall be provided for each five (5) pupils. Floors shall be drained in such a manner that waste water from any shower head will not pass over areas occupied by other bathers. Showers must be kept clean & free of mildew. Foot baths are not allowed.

Inspection Conducted By: Sherri Bruner (67170)

Phone:

Received By: Signed

Date: 9/9/2015

Inspector Signature:

Handwritten signature of Sherri Bruner in black ink.

Client Signature:

Handwritten signature in black ink.

Form Number: DH 4030 01/05